

Issue Date: 01-07-2015
Revision Date: 03-30-2026
Renewal Date: 03-31-2027

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION

Section: 07 21 00 – Thermal Insulation

Section: 07 21 19 – Foamed-In-Place Insulation

REPORT HOLDER:

BASF Corporation
1703 Crosspoint Avenue
Houston, Texas 77054
(888) 900-FOAM
www.spf.basf.com

REPORT SUBJECT:

ENERTITE® G, ENERTITE® X and ENERTITE® Max Spray-applied Polyurethane Foam Insulation

1.0 SCOPE OF EVALUATION

This Research Report addresses compliance with the following Codes:

- 2021, 2018, 2015 *International Building Code®* (IBC)
- 2021, 2018, 2015 *International Residential Code®* (IRC)
- 2021, 2018, 2015 *International Energy Conservation Code®* (IECC)
- 2023 and 2020 *Florida Building Code* – see Section 8.1
- 2022 *California Building Code* – see Section 8.2

NOTE: This report references the most recent edition of the codes cited. Section numbers in earlier editions of the codes may differ.

ENERTITE® G, ENERTITE® X and ENERTITE® Max Open-Cell Spray Polyurethane Foam Insulations have been evaluated for the following properties:

- Physical properties
- Surface-burning characteristics
- Thermal resistance
- Air permeability
- Alternatives to thermal barriers
- Alternatives to ignition barriers
- Use in Types I, II, III and IV construction
- Use in Type V construction
- Use in fire-resistance-rated construction

See Table 1 for applicable Code sections related to these properties.

2.0 USES

2.1 ENERTITE® G, ENERTITE® X and ENERTITE® Max:

ENERTITE® G, ENERTITE® X, and ENERTITE® Max insulations are intended for use as nonstructural thermal insulating materials on or in interior and exterior walls, floors, and the underside of roofs, in all types of construction under the IBC and dwellings under the IRC. When used in exterior walls of Types I, II, III, or IV construction, the construction must be as described in Section 4.5. Under the IRC, the insulation may be used as air-impermeable insulation as described in Section 3.3.3. The insulations may be used in attics and crawl spaces without the use of a prescriptive ignition barrier when installed as described in Section 4.4.2. The insulations may be applied without the use of a prescriptive thermal barrier when installed as described in Section 4.3.2.

3.0 DESCRIPTION

3.1 Insulation:

3.1.1 ENERTITE® G, ENERTITE® X and ENERTITE® Max: ENERTITE® G, ENERTITE® X, and ENERTITE® Max are two-component, open-cell, water-blown polyurethane foam plastic insulations. The insulations comply with the mandatory requirements for low-density insulation applications described in Section 3.1.1 and Table 1 of ICC-ES AC377. The insulations are produced in the field by professional contractors combining an isocyanate component "A" with a resin component "B". The insulations use an A component designated as ELASTOSPRAY® 8000A and uses a proprietary blend for the B component. The B component has a shelf life of six months and the A component has a shelf life of twelve months, when stored in factory-sealed containers at temperatures between 50°F and 80°F.



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

intertek.com/building



PCA-101



3.2 Intumescent Coatings:

3.2.1 No-Burn® Plus ThB: No-Burn® Plus ThB is a one-part water-based intumescent coating manufactured by No-Burn, Inc. The coating is supplied in 5-gallon pails and 55-gallon drums and has a shelf life of 12 months when stored in unopened containers between 40°F and 90°F. No-Burn® Plus ThB complies with ICC-ES AC456 as recognized in IAPMO Uniform Evaluation Service Report ER-0305.

3.2.2 DC315 Intumescent Coating: DC315 intumescent coating, manufactured by International Fireproof Technology Inc., is a single-component, water-based, liquid-applied intumescent coating. The coating is supplied in 5-gallon pails and 55-gallon drums and has a shelf life of twenty-four months when stored in factory-sealed containers at temperatures between 41°F and 95°F. DC315 complies with ICC-ES AC456 as recognized in IAPMO UES Report ER-0499.

3.2.3 FIRESHELL® (IB-4) Coating: FIRESHELL® (IB-4) intumescent coating is a proprietary, water-based, one-part, nonflammable coating manufactured by ICP Construction. The coating is supplied in 5-gallon pails and 55-gallon drums, and has a shelf life of twelve months when stored in factory-sealed containers at temperatures between 45°F and 75°F.

3.2.4 FIRESHELL® (F10E) Coating: FIRESHELL® (F10E) intumescent coating is a proprietary, water-based, one-part, coating manufactured by ICP Construction. The coating is supplied in 5-gallon pails and 55-gallon drums and has a shelf life of twelve months when stored in factory-sealed containers at temperatures between 45°F and 75°F. Fireshell® F10E complies with ICC-ES AC456 as recognized in ICC Evaluation Service Report ESR-3997.

3.3 Performance Characteristics:

3.3.1 Surface Burning Characteristics: ENERTITE® G, ENERTITE® X and ENERTITE® Max have a flame-spread index of 25 or less and a smoke-developed index of 450 or less, when tested in accordance with ASTM E84 at a maximum thickness of 4 inches. Based on diversified large-scale tests, the insulations may be installed at greater thicknesses as described in Sections 4.3 and 4.4. When the insulation is separated from the interior living space of the building with minimum 1/2-inch-thick gypsum board, or an equivalent thermal barrier, the

maximum insulation thickness is not limited. Under the IRC, a thermal barrier of minimum 23/32-inch-thick wood structural panel is also permitted and the maximum insulation thickness is not limited.

3.3.2 Thermal Resistance: The insulations have thermal resistance (*R*-values) at a mean temperature of 75°F as shown in Table 2.

3.3.3 Air Permeability: ENERTITE® G, ENERTITE® X, and ENERTITE® Max (at a minimum thickness of 3-1/2 inches), are considered air-impermeable insulation in accordance with IBC Section 202 and IRC Section R202, based on testing in accordance with ASTM E283 and ASTM E2178.

3.3.4 Air Barrier: ENERTITE® G, ENERTITE® X, and ENERTITE® Max (at a minimum thickness of 3-1/2 inches), are considered air barrier materials in accordance with IECC Section C402.5.1.3.

4.0 INSTALLATION

4.1 General:

The insulation must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. The manufacturer's published installation instructions and this Research Report must be strictly adhered to, and a copy of the instructions must be available on the jobsite during installation.

4.2 Application:

The insulations are spray-applied on the jobsite using plural-component metering and processing equipment as recommended in the manufacturer's published installation instructions. The insulation must not be used in areas that have a maximum continuous service temperature greater than 180°F or in contact with heat-producing appliances. The foam plastic insulation must not be used in electrical outlet or junction boxes. The substrate must be free of moisture, frost or ice, loose scales, rust, oil, and grease or other surface contaminants. The insulation must be protected from the weather during and after application. The insulation can be installed in multiple passes, up to 6 inches per pass, to the maximum specified thickness. Where multiple passes are required, each insulation pass must be allowed to fully expand,



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

intertek.com/building

Internal



PCA-101



cure, and cool for a minimum of 5 minutes prior to application of a subsequent pass.

4.3 Thermal Barrier:

4.3.1 Application with a Prescriptive Thermal Barrier:

The insulations must be separated from the interior of the building by an approved thermal barrier, such as minimum 1/2-inch gypsum wallboard, installed using mechanical fasteners in accordance with applicable Code, or an equivalent 15-minute thermal barrier complying with IBC Section 2603.4 or IRC Section R316.4, as applicable, with exceptions as described in Sections 4.3.2 and 4.4, or when applied to a sill plate or header of Type V construction at a maximum insulation thickness of 3-1/4 inches as permitted by IRC Section R316.5.11. When the insulation is separated from the interior living space of the building with minimum 1/2-inch-thick gypsum board, the maximum insulation thickness is not limited. Under the IRC, a thermal barrier of minimum 23/32-inch-thick wood structural panel is also permitted and the maximum insulation thickness is not limited.

4.3.2 Application without a Prescriptive Thermal Barrier: ENERTITE® G, ENERTITE® X, and ENERTITE® Max may be installed without the 15-minute thermal barrier prescribed in the IBC Section 2603.4 and IRC Section R316.4, subject to the following conditions:

- a. All surfaces of the ENERTITE® G, ENERTITE® X, or ENERTITE® Max insulation must be covered with No-Burn® Plus ThB, Fireshell F10E or DC315 intumescent coating as follows:
 - No-Burn® Plus ThB: minimum application rate of 14 wet mils (0.87 gallons per 100 ft²)
 - Fireshell F10E: minimum application rate of 18 wet mils (1.18 gallons per 100 ft²)
 - DC315: minimum application rate of 18 wet mils (1.12 gallons per 100 ft²)
- b. The ENERTITE® G, ENERTITE® X, or ENERTITE® Max insulation shall have a maximum installed thickness as follows:
 - No-Burn® Plus ThB: 8 inches in vertical walls and 14 inches in ceilings
 - Fireshell F10E: 9-1/2 inches in vertical walls and 11-1/2 inches in ceilings
 - DC315: 7-1/2 inches in vertical walls and 14-1/2 inches in ceilings

4.4 Attics and Crawl Spaces:

4.4.1 Application with a Prescriptive Ignition Barrier:

When the insulations are installed within attics or crawl spaces, where entry is made only for service of utilities, an ignition barrier must be installed in accordance with IBC Section 2603.4.1.6 or IRC Section R316.5.3 or R316.5.4, as applicable. The ignition barrier must be consistent with the requirements for the type of construction required by the applicable Code and must be installed in a manner so that the foam plastic insulation is not exposed.

4.4.2 Application without a Prescriptive Ignition Barrier:

The insulations may be installed in an attic or crawl space without the prescriptive ignition barrier described in IBC Section 2603.4.1.6 and IRC Sections R316.5.3 and R316.5.4, when all of the following conditions apply:

- a. Entry to the attic or crawl space is only for the service of utilities and no storage is permitted.
- b. There are no interconnected attic or crawl space areas.
- c. Air in the attic or crawl space is not circulated to other parts of the building.
- d. Attic ventilation is provided when required by IBC Section 1202.2 or IRC Section R806, except air-impermeable insulation is permitted in unvented attics in accordance with IBC Section 1202.3 or IRC Section R806.5.
- e. Under-floor (crawl space) ventilation is provided when required by IBC Section 1202.4 or IRC Section R408.1, as applicable.
- f. Combustion air is provided in accordance with IMC (*International Mechanical Code*) Section 701.

4.4.2.1 Attics and Crawl Spaces: In attics, the insulation may be spray-applied to the underside of roof sheathing or roof rafters, and/or vertical surfaces provided the assembly conforms to one of the assemblies described in Table 3. In crawl spaces, the insulation may be spray-applied to the underside of floors and/or vertical surfaces provided the assembly conforms to one of the assemblies described in Table 3. When an intumescent coating is used, surfaces to be coated must be dry, clean, and free of dirt, loose debris, and any other substances that could interfere with adhesion of the coating. The intumescent coating must be applied to all surfaces in accordance with the respective coating manufacturer's installation instructions. The coating must be applied when ambient and substrate temperatures are above of 50°F unless otherwise permitted by the intumescent coating





manufacturer's installation instructions. The insulation may be installed in unvented attics as described in this section and in accordance with IBC Section 1202.3 or IRC Section R806.5 at a minimum thickness of 3-1/2 inches.

4.4.2.2 Unvented Attics: BASF Corporation has conducted end use configuration testing (per IBC Section 2603.9 and IRC Section R316.6) and analysis to qualify the use of ENERTITE® G and ENERTITE® Max insulations without a prescriptive ignition barrier or intumescent coating in unvented attics conforming with IBC Section 1202.3 or IRC Section R806.5. The testing and analysis are described in Priest & Associates EEV 10419 Revision 1b, dated June 26, 2023. The conclusions of that evaluation are as follows: When ENERTITE® G or ENERTITE® Max is applied in unvented attics conforming to IBC Section 1202.3 or IRC Section R806.5, the insulation may be applied to the underside of roof sheathing and/or rafters and to vertical surfaces to a minimum thickness of 3-1/2 inches. Rafters may be left without foam coverage or may be covered with foam up to the maximum thickness allowed. Maximum thickness on the underside of roof sheathing or on vertical wall surfaces is 16 inches. The insulation may be left exposed to the attic without a prescriptive ignition barrier or an intumescent coating. The attic must have attic access complying with IRC Section R807, horizontally placed in the attic floor and opening outward toward the living space. For items penetrating the roof deck or walls, such as skylight wells or vents, the penetrating item exposed in the attic must be covered with a minimum of 1-1/2 inches of ENERTITE® G or ENERTITE® Max insulation.

4.4.2.3 Use on Attic Floors: ENERTITE® G and ENERTITE® Max insulation may be installed exposed (without a protective covering) in attic floors, between and over joists, at a maximum thickness of 6 inches. ENERTITE® G and ENERTITE® Max may also be installed in attic floors, between and over joists, with intumescent coatings and maximum thickness as indicated in Table 3. ENERTITE® X may be installed exposed (without a protective covering) in attic floors, between and over joists, at a maximum thickness of 8 inches. The ignition barrier required in IBC Section 2603.4.1.6 or IRC Section R316.5.3 may be omitted. The insulation must be separated from the interior of the building by an approved thermal barrier.

4.5 Exterior Walls in Types I, II, III, and IV Construction:

ENERITE® G, ENERTITE® X, and ENERTITE® Max insulation may be installed in or on the interior side of exterior walls of buildings of Types I, II, III, and IV construction complying with IBC Section 2603.5 and as described in this section. The maximum thickness of the foam plastic is 6 inches when installed in stud cavities. The maximum potential heat of ENERTITE® G and ENERTITE® Max is 656 Btu/ft² per inch of thickness, and for ENERTITE® X is 644 Btu/ft² per inch of thickness. The tested wall assembly was extended through a third-party engineering analysis to include additional wall constructions described in Table 4. Additional wall assemblies complying with IBC Section 2603.5 containing ENERTITE® G, ENERTITE® X, and ENERTITE® Max are described in CCRR-1031.

4.6 Fire-Resistance-Rated Construction:

ENERTITE® G and ENERTITE® Max spray-applied insulations have been tested for compliance with UL 263 (ASTM E119). Refer to the UL LLC Fire-resistance Directory at <https://productiq.ulprospector.com/en>. The UL design listings have not been evaluated under this Research Report.

5.0 CONDITIONS OF USE

The spray-applied polyurethane foam insulations described in this Research Report comply with, or are suitable alternatives to, what is specified in those Codes listed in Section 1.0 of this report, subject to the following conditions:

5.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict between the manufacturer's instructions and this report, this report governs.

5.2 The insulation must be separated from the interior of the building by an approved 15-minute thermal barrier as described in Section 4.3.1, except as described in Sections 4.3.2 and 4.4.

5.3 The installed thickness must not exceed that noted in Sections 3.2, 4.3, 4.4, and 4.5.





5.4 The insulation must be protected from the weather during and after application.

5.5 The insulation must be applied by professional spray polyurethane foam installers approved by BASF Corporation or by the Spray Polyurethane Foam Alliance (SPFA) for the installation of spray polyurethane foam insulation.

5.6 When ENERTITE® G or ENERTITE® Max insulation is installed under the conditions of Section 4.4.2.2 of this report, the following conditions apply:

5.6.1 Since the performance of ENERTITE® G and ENERTITE® Max, when installed in unvented attics without a Code-prescribed ignition barrier or an intumescent coating, are based on fire performance of an unvented attic, the installation must be approved by the Code official. The installation must conform with the provisions of Section 4.4.2.2 and Conditions a. through c., and Condition f. of Section 4.4.2. A copy of the Priest & Associates Engineering Evaluation (referenced in Section 6.7) must be provided to the Code official by the manufacturer upon request.

5.6.2 Signage shall be permanently affixed in the attic and shall be visible from all points within the attic. The sign shall state *"Caution, this is an unvented attic by design. No modification may be made to this unvented condition. The attic shall not be vented. Holes into the unvented attic shall be immediately repaired and sealed. Penetrations of the ceiling or wall membrane between the unvented attic and living space, other than the horizontal access hatch, must be protected in an approved manner. This unvented attic shall not be used for storage. See Intertek Code Compliance Research Report CCRR-1032 on the [Intertek Website](#)."*

5.7 Use of the insulation in areas where the probability of termite infestation is "very heavy" must be in accordance with IBC Section 2603.8 or IRC Section R305.4, as applicable.

5.8 Jobsite certification and labeling of the insulation must comply with IRC Section N1101.10, N1101.14 and IECC Sections C303.1 or R303.1 and R401.3, as applicable.

5.9 A vapor retarder must be installed in accordance with the applicable Code.

5.10 The insulation components are manufactured under a quality control program with inspection by Intertek Testing Services NA, Inc.

6.0 SUPPORTING EVIDENCE

6.1 Reports of tests in accordance with ASTM C518, ASTM E84, ASTM E283, ASTM E970, ASTM E2178, NFPA 259, NFPA 285, and NFPA 286.

6.2 Data in accordance with the ICC-ES Acceptance Criteria for Spray-applied Foam Plastic Insulation (AC377), dated February 2020, including reports of tests in accordance with Appendix X.

6.3 Data in accordance with ICC 1100 (2019).

6.4 Research Reports for evaluation of data in accordance with ICC-ES Acceptance Criteria for Fire-protective Coatings Applied to Spray-applied Foam Plastic Insulation Installed without a Code-prescribed Thermal Barrier (AC456), dated October 2015.

6.5 Intertek Listing Report "[BASF Corporation ENERTITE® G, ENERTITE® X, and ENERTITE® Max](#)" on the Intertek Directory of Building Products.

6.6 Hughes Associates, Inc. letters, dated April 14, 2014, and October 07, 2014, Re: HAI Project 1JJB00019.001.

6.7 Priest & Associates Engineering Evaluation 10419 Revision 1b, dated June 26, 2023.

6.8 Priest & Associates Engineering Letter 40103G, dated July 18, 2017.

7.0 IDENTIFICATION

Each container of components A and B of the insulation bears a label with the BASF Corporation name and address; the product name; the flame-spread and smoke-developed indices; the expiration date, the Intertek Mark; and the Research Report number (CCRR-1032). Intumescent coatings are identified with the manufacturer's name and address, the product trade name and use instructions.





8.0 OTHER CODES

8.1 Florida Building Code:

8.1.1 Scope of Evaluation: ENERTITE® G, ENERTITE® X, and ENERTITE® Max have been evaluated under the 2023 and 2020 *Florida Building Codes: Building, Residential and Energy Conservation*.

8.1.2 Conclusions: The products described in Sections 2.0 through 7.0 comply with the 2023 and 2020 *Florida Building Codes: Building, Residential, and Energy Conservation*, including High-Velocity Hurricane Zones, when installation is as described in Sections 2.0 through 7.0 of this Research Report.

8.1.3 The products are under a quality assurance program audited by Intertek.

8.1.4 Intertek is an approved evaluation entity and quality assurance entity pursuant to Florida Statute 553.842 – *Product Evaluation and Approval*

8.2 California Building Code:

8.2.1 Scope of Evaluation: ENERTITE® G, ENERTITE® X, and ENERTITE® Max have been evaluated under the 2022 *California Building Code (CBC)*, 2022 *California Residential Code (CRC)* and 2022 *California Energy Code (CEC)*.

8.2.2 Conclusions: The products described in Sections 2.0 through 7.0 comply with the 2022 *California Building Code (CBC)*, 2022 *California Residential Code (CRC)* and 2022 *California Energy Code (CEC)*, subject to the following conditions:

8.2.2.1 In accordance with Section 110.8 of the 2022 *California Energy Code*, verification of certification by the Department of Consumer Affairs, Bureau of Home Furnishings and Thermal Insulation, must be provided to the Code official, demonstrating that the insulation

thermal performance is approved pursuant to the California Code of Regulations, Title 24, Part 12, Chapters 12-13, Article 3, "Standards for Insulating Material".

8.2.2.2 When installed in accordance with Sections 2.0 through 7.0 of this report, the insulations may be used in areas designated a Fire Hazard Zone within a State Responsibility Area or Wildland-urban Interface Fire Area under CBC Chapter 7A and CRC Section 337. When used in exterior walls, the foam plastic must be (a) covered with an exterior wall covering complying with CBC Section 707A.3 or CRC Section R337.7.3, or (b) part of a tested assembly complying with the requirements of CBC Section 707A.4 or CRC Section R337.7.4.

9.0 CODE COMPLIANCE RESEARCH REPORT USE

9.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

9.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

9.3 Reference to the <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

[intertek.com/building](https://www.intertek.com/building)

Internal



PCA-101



TABLE 1A – PROPERTIES EVALUATED – INTERNATIONAL CODES

PROPERTY	2021 IBC SECTION ¹	2021 IRC SECTION ¹	2021 IECC SECTION ¹
Physical properties	2603.1.1	Not required	Not required
Surface-burning characteristics	2603.3	R316.3	Not applicable
Alternative to thermal barrier/ignition barrier	2603.4	R316.4	Not applicable
Air permeability	1202.3	R806.5	C402.5 R402.4
Fire-resistance-rated construction	703	R302	Not applicable
Exterior walls in Types I-IV construction	2603.5	Not applicable	Not applicable
Thermal resistance	1301	N1101.10 N1102	C303.1 R303.1

¹ Section numbers may be different for earlier versions of the International Codes.

TABLE 1B – PROPERTIES EVALUATED – FLORIDA BUILDING CODES

PROPERTY	2023 FBC – BUILDING SECTION	2023 FBC - RESIDENTIAL SECTION	2023 FBC – ENERGY SECTION
Physical properties	2603.1.1	Not required	Not required
Surface-burning characteristics	2603.3	R316.3	Not applicable
Alternative to thermal barrier/ignition barrier	2603.4	R316.4	Not applicable
Air permeability	1203.3	R806.5	C402.5 R402.4
Fire-resistance-rated construction	703	R302	Not applicable
Exterior walls in Types I-IV construction	2603.5	Not applicable	Not applicable
Thermal resistance	1301	See FBC - Energy	C303.1 R303.1



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

intertek.com/building

PCA-101



TABLE 1C – PROPERTIES EVALUATED – CALIFORNIA BUILDING CODES

PROPERTY	2022 CBC SECTION	2022 CRC SECTION	2022 CEC SECTION
Physical properties	2603.1.1	Not required	Not required
Surface-burning characteristics	2603.3	R316.3	Not applicable
Alternative to thermal barrier/ignition barrier	2603.4	R316.4	Not applicable
Air permeability	1202.3	R806.5	140.3
Fire-resistance-rated construction	703	R302	Not applicable
Exterior Wildfire Exposure	707A	R337.7	Not applicable
Exterior walls in Types I-IV construction	2603.5	Not applicable	Not applicable
Thermal resistance	Referred to California Energy Code	Referred to California Energy Code	110.8



TABLE 2 – THERMAL RESISTANCE^{1,2,3}

THICKNESS (inches)	R-VALUE (°F·ft ² ·h/Btu)	
	ENERTITE® G, ENERTITE® Max	ENERTITE® X
1	3.9	4.0
2	7.6	7.6
3	11	11
3.5	13	13
4	15	14
5	19	18
5.5	20	20
6	22	21
7	26	25
7.5	28	27
8	30	29
9	33	32
9.5	35	34
10	37	36
11.5	43	41
12	45	43
16	59	NA

¹ R-values are calculated based on the test K values at 1-and 4-inch thicknesses.

² R-values greater than 10 are rounded to the nearest whole number.

³ To determine R values for thickness not listed:

- a. Between 1 inch and 4 inches can be determined through linear interpolation; or,
- b. ENERTITE® G and Max: Greater than 4 inches can be calculated based on R= 3.71/inch
- c. ENERTITE® X: Greater than 3.5 inches can be calculated based on R = 3.58/inch



Intertek

Version: 11 November 2021

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

intertek.com/building

Internal



PCA-101

SFT-BC-CCRR-OP-19a Code Compliance Research Report



TABLE 3 – USE OF INSULATION IN ATTICS AND CRAWL SPACES WITHOUT A PRESCRIPTIVE IGNITION BARRIER

INSULATION TYPE	MAXIMUM THICKNESS (inches) (Wall Cavities and Attic Floor)	MAXIMUM THICKNESS (inches) (Underside of Roof Sheathing/ Rafters and Floors)	INTUMESCENT COATING, MINIMUM THICKNESS & TYPE (Applied to all Exposed Foam Surfaces)	MINIMUM APPLICATION RATE OF INTUMESCENT COATING	TEST SUBMITTED (AC377)
ENERTITE® G, ENERTITE® Max	9-1/2	11-1/2	FIRESHELL® (IB-4) 5 wet mils (3.5 dry mils)	0.31 gal / 100 ft ²	Appendix X
	11-1/2	15-1/2	DC315 4 wet mils (3 dry mils)	0.25 gal / 100 ft ²	Appendix X
ENERTITE® X	8	12	None	N/A	Appendix X





TABLE 4 – NFPA 285 COMPLYING WALLS – ENERTITE® G, ENERTITE® X, OR ENERTITE® MAX IN INTERIOR WALL CAVITY

Wall Component	Materials
Base wall system – Use either 1, 2 or 3	<ol style="list-style-type: none"> 1 - Concrete wall 2 - Concrete Masonry wall 3 - One layer of 5/8-inch thick Type X gypsum wallboard installed on the interior side of minimum 3-5/8-inch-deep minimum 20-gauge-thick steel studs spaced a maximum of 24-inch on center. Lateral bracing installed minimum every 4 ft. vertically or as required. Wall stud cavities shall be filled at each floor line with minimum 4 lb/ft³ mineral wool (e.g., Thermafiber) friction fit between steel wall studs.
Perimeter Fire Barrier System	Perimeter fire barrier system complying with IBC Section 715.4 shall be installed, as applicable, to fill the linear gap between the edge of the concrete floor slab and the interior surface of the exterior wall assembly.
Interior Insulation – Use either 1, 2, 3, 4 or 5 or combinations of 3 with 4 or 3 with 5	<ol style="list-style-type: none"> 1 - None 2 - Maximum 6-inch thickness of ENERTITE® G, ENERTITE® X, or ENERTITE® Max applied to interior surface of Base Wall System 1 and 2 (See Note 1) 3 - Full wall stud cavity depth or less of ENERTITE® G, ENERTITE® X, or ENERTITE® Max applied using exterior gypsum sheathing of Base Wall System 3 as the substrate and covering the width of the cavity and the inside of the steel wall stud framing flange. 4 - Fiberglass batt insulation (faced or unfaced) 5 - Mineral wool insulation (faced or unfaced)
Exterior sheathing	5/8-inch-thick Type X exterior type gypsum sheathing (for Base Wall System 3 above)
Exterior Wall Covering – Use either 1, 2 or 3 (See Note 2)	<ol style="list-style-type: none"> 1 – Any non-combustible exterior wall covering material using any standard installation technique 2 – Any non-combustible exterior wall covering system with a combustible WRB that has successfully been tested in accordance with NFPA 285 3 – Any combustible exterior wall covering system with or without a combustible WRB that has been successfully tested in accordance with NFPA 285
Flashing of window, door and other exterior wall penetrations.	As an option, flash around window, door and other exterior penetrations with limited amounts of maximum 12-inch-wide flashing tape (acrylic, asphalt or butyl-based) or liquid applied membrane material with or without fiber mesh reinforcement.

Note 1: Fireblocking per IBC Section 718 and thermal barrier material requirements must be met for Base Wall Systems 1 and 2, as required by specific wall construction details when combustible concealed space is created on interior side of exterior wall assembly.

Note 2: Combustible exterior wall coverings shall be installed in accordance with manufacturer's requirements.



Intertek

Version: 11 November 2021

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

intertek.com/building

Internal



PCA-101

SFT-BC-CCRR-OP-19a Code Compliance Research Report